



Lakeshore Company
3 Trails End
Morristown, NJ 07960

March 23rd, 2009

RE: Lakeshore Company System Outline

Dear Lakeshore Company,
As requested by Mr. Rick Barrett, of the Lakeshore Company, the following is a brief overview of the Lakeshore water system and its components.

The Lakeshore Company is identified as a Community Water system as per NJDEP-BSDW rules. The Public Water system ID Number is NJ14130001. There are at present 94 residential connections, plus a common building "Clubhouse" connection. There is also a connection at the community garden plot and tennis court area. The approximate system population is 300 persons.

There are two wells that supply water to the system, and one well that is not being used at the present time. Both of the wells in use are good producers, and have shown water testing results consistent with NJDEP-BSDW requirements. Both of the in-use wells are located within a heated well house, are metered, and have installed sodium hypochlorite disinfection systems.


A generator ready, transfer switch system, has been installed at well house #1 for emergency power.

Water is pumped via the distribution system to three atmospheric storage tanks of approximately 10,000 gallons each. These tanks are in serviceable condition. There are functioning valves at this site to shut off the water flow, but no electrical power at this time. The tanks have recently received an epoxy paint coating.

The majority of distribution main lines are cast iron water pipe, four inches in diameter, in good condition based on recent inspection of sections near the number one well house. There is a section of recently replaced plastic pipe. There are hydrants and shut off valves located at various intervals throughout the system. These have been kept in good repair, and have been recently flushed and exercised.

There are shut-off valves for almost all the residences and the system has maps available for these locations. The distribution system, valves, hydrants and storage tank layout has been mapped.

Best Regards,

A handwritten signature in black ink, appearing to read 'M. Huber', is written over a long, thin horizontal line that spans across the page.

Max J. Huber / Agra Environmental & Laboratory Services
90 ½ West Blackwell Street, Dover, NJ 07801
973-989-0010